

# STORMWATER POST-CONSTRUCTION TREATMENT DEVICE OPERATIONS & MAINTENANCE

## Fire Station # 45 790 Pacific Ave, Simi Valley

Devices On-Site:  
Three (3) Catch Basin Inserts



# Operations & Maintenance Plan

Date: \_\_\_\_\_ O & M Personnel: \_\_\_\_\_ Signature: \_\_\_\_\_

O & M Frequency:     Pre-Wet Season (before Oct 1)     Post-Wet Season (after April 15)     After Storm

Catch Basin Insert			
Activity	O & M Needed	O & M Completed	Comments / Maintenance Performed
Remove Trash/Debris/Sediment			
Inspect for Tears, Holes, Bending, and Missing Hangers			
Replace Filter Medium Pouches Annually			

<http://www.kristar.com/index.php/drain-inlet-filtration/flogard-plus-catch>

\*(1) Model # FF-18D; (1) Model # FGP-18F; (1) Model # FGP 16F